



Jersey

**FIRE RESISTING STRUCTURES
(EXPLOSION PRESSURE RELIEF)
(JERSEY) ORDER 1980**

Official Consolidated Version

This is an official version of consolidated legislation compiled and issued under the authority of the Legislation (Jersey) Law 2021.

05.300.25

Showing the law from 1 January 2019 to Current



Jersey

FIRE RESISTING STRUCTURES (EXPLOSION PRESSURE RELIEF) (JERSEY) ORDER 1980

Contents

Article

1	5
2	5
3	5

SCHEDULE **6**

FIRE RESISTING STRUCTURES REQUIRING EXPLOSION PRESSURE RELIEF	6
---	---

ENDNOTES **7**

Table of Legislation History	7
Table of Endnote References	7



Jersey

FIRE RESISTING STRUCTURES (EXPLOSION PRESSURE RELIEF) (JERSEY) ORDER 1980

The **EMPLOYMENT AND SOCIAL SECURITY COMMITTEE**, in pursuance of Article 9 of the [Health and Safety at Work \(Jersey\) Law 1989](#) and Regulation 10 of the [Safeguarding of Workers \(Highly Flammable Liquids\) \(Jersey\) Regulations 1979](#), orders as follows –

Commencement [[see endnotes](#)]

1

Provision for pressure relief in the case of explosion shall be made in the structure of a fire resisting structure listed in the Schedule.

2

Provision for adequate natural ventilation shall be made in any store room which is –

- (a) a fire resisting structure within the meaning of Regulation 1(1) of the Regulations; and
- (b) used for storing 50 litres or more of highly flammable liquids.

3

This Order may be cited as the Fire Resisting Structures (Explosion Pressure Relief) (Jersey) Order 1980.

SCHEDULE

FIRE RESISTING STRUCTURES REQUIRING EXPLOSION PRESSURE RELIEF

Low bake vehicle refinishing unit used for the painting of cars and commercial vehicles.

ENDNOTES

Table of Legislation History

Legislation	Year and No	Commencement
Fire Resisting Structures (Explosion Pressure Relief) (Jersey) Order 1980	R&O.6818	1 July 1980

Table of Endnote References

There are currently no endnote references